

**Government of Bihar  
Public Health Engineering Department  
Monthly Water Quality Monitoring Report**

Sample Collected By:- Chemist(Mukesh Kumar Bhagat)

Sub Division Name: P.H.Sub-Division, Bihiya

Month:- May 2023

Sl. No.	Block	Panchayat	Village	Ward No	Date of Sampling	Date of Testing	Type Of Source	Location of Source	PH	Turb	EC	TDS	TH	CL	Alka	As	Remarks
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
1	Jagdishpur	Dawa	Lalatola	2	20-05-2023	23-05-2023	Handpump	Vivekanand Public School	7.27	0.9	295	191	102	15	118	BDL	Safe
2	Jagdishpur	Dawa	Lalatola	2	20-05-2023	23-05-2023	Samarsable	Vivekanand Public School	7.32	1.2	345	220	114	22	126	BDL	Safe
3	Jagdishpur	Dawa	Lalatola	2	20-05-2023	23-05-2023	R O Water	Vivekanand Public School	7.12	0.3	165	104	60	11	74	BDL	Safe
									6.5-8.5	1	-	500	200	250	200	0.01	
									NR	5	-	2000	600	1000	600	NR	

In case of new please indicate in column 18

*Mukesh Kumar Bhagat*  
Chemist  
P.H.Sub-Division, Bihiya  
26/05/23

*Principal*  
VIVEKANAND PUBLIC SCHOOL  
Bihiya-Jagdishpur Road  
Bhojpur, Bihar

*Ram Prasad*  
26/5/2023  
S.E. Bihiya

JUNIOR ENGINEER  
P.H. SECTION  
(BIHIYA)

*Ram Prasad*  
Manager  
VIVEKANAND PUBLIC SCHOOL  
BIHIYA-JAGDISHPUR